



'C' BOTTOM CLUSTER-9

GROUND FLOOR

SHAFT

SSCU - 5
HEAVY EQUIPMENT

EAST SIDE NORTH WING

C BOTTOM

EAST SIDE SOUTH WING

SHAFT

SSCU - 5
HEAVY EQUIPMENT

VENT POINT FOR STORE ROOM

LEGENDS:-

NOTE: 1) DUCT / PIPE SIZES OF 180mm OD (160mm ID & BELOW ARE OF PP-4 / SIKR 26 PP / PPH PIPES (FACTORY FABRICATED)
2) DUCT / PIPE SIZES ABOVE 200mm OD (180mm ID) ARE OF PP NATURAL WITH FRP (FABRICATED DUCTS)
3) THE EXIST SIZES IN THE AREAS OF DRAGGERS IS ONLY PERTAINING REPRESENTATIONS AND NOT ACTUAL IT WILL BE AS PER THE APPROVED DRAWING
4) SILENCER, SOLVENT STORAGE CABINET & GLOVE BOX IS FITTED WITH CAN, CAN IS PART OF LAB FURNITURE.

PROJECT:

LABORATORY INTERIOR WORKS FOR
CHEMICAL SCIENCES BUILDING.

DRAWING TITLE:

EXHAUST P & ID FOR CLUSTER - 9

CLIENT:

INDIAN INSTITUTE OF SCIENCE,
BANGALORE.



Architect:
Chandroo Iyer Associates
NO 68, 19TH 'A' CROSS, 6TH MAIN
MULSTANALI
BANGALORE 560 055.
TEL. - 86- 23368319

Consultant:

PROJECT ENGINEERING CONSULTANTS
4th FLOOR, 4TH MAIN ROAD,
VARDHANNAPUR, BANGALORE 560 032
TEL:-22234453/22234453/0
E-mail:proj@mjassociates.com,proj@mjassociates.com

DRAWN	KIRAN
CHECKED	SESHADRI
APPROVED	SUNDAR
DATE	13.03.2019
JOB NO	MJ - 324
DWG NO:	2608
SCALE	NTS
REVISION	TR 0