

1/4"OD-FUT-SS2

1/4"OD-FUT-SS2

INLET PRESSURE=14 bar
OUTLET PRESSURE=0-2 BAR



INLET PRESSURE=150 bar
OUTLET PRESSURE=14 BAR

CLIENT SCOPE.

FUT

GAS BANK AREA

LEGEND	
FUT	FUTURE GAS
SS2	SS316
SS1	SS304
CPVC	CHLORINATED POLYVINYL CHLORIDE
PIPE IDENTIFICATION	
PIPE SIZE	1/4"OD-FUT-SS2
SERVICE	MOC
VALVE IDENTIFICATION	
1. VALVE SPECIFICATION	
VALVE TYPE	BV- 01
2. NV - NEEDLE VALVE	TAG NO.
3. BV - BALL VALVE	
4. CV - NON RETURN VALVE	

CLIENT:	 INDIAN INSTITUTE OF SCIENCE, BANGALORE.	Architect:	Chandoo Iyer Associates NO 69, 15TH "A" CROSS, 6th MAIN MALESWARAM BANGALORE 560 055 TEL - 80 23368319	DRAWN	ABHI
				CHECKED	BGK
PROJECT:	LABORATORY INTERIOR WORKS FOR CHEMICAL SCIENCES BUILDING.	Consultant:	 M J ASSOCIATES PROJECT ENGINEERING CONSULTANTS #45, 1st Floor, 2nd Main road, Vasanth nagar, Bangalore-560 052 Tele-22284583,22204836 E-mail-projects@mjasociates.in/www.mjasociates.in	APPROVED	SUNDAR
				DATE	24.03.2019
				JOB NO	MJ - 324
				DWG NO:	4812 (i)
				SCALE	NTS
DRAWING TITLE:	P&ID FOR FUTURE GAS FOR IPC-5	DRAWING STATUS : TENDER DRAWINGS		REVISION	TR 0