

1/4"OD-FUT-SS2


1/4"OD-FUT-SS2

PR-01
BV-01



INLET PRESSURE=14 bar
OUTLET PRESSURE=0-2 BAR

INLET PRESSURE=150 bar
OUTLET PRESSURE=14 BAR

CLIENT SCOPE.



LEGEND	
FUT	FUTURE GAS
SS2	SS316
SS1	SS304
CPVC	CHLORINATED POLYVINYL CHLORIDE
PIPE IDENTIFICATION	
1/4"OD-FUT-SS2	
PIPE SIZE	MOC
SERVICE	
VALVE IDENTIFICATION	
1. VALVE SPECIFICATION	
VALVE TYPE	BV- 01
2. NV - NEEDLE VALVE	TAG NO.
3. BV - BALL VALVE	
4. CV - NON RETURN VALVE	

CLIENT:	 INDIAN INSTITUTE OF SCIENCE, BANGALORE.	Architect: Chandroo Iyer Associates NO 69, 15TH "A" CROSS, 6th MAIN MALLESWARAM BANGALORE 560 053. TEL - 80 - 23360319	Consultant:  PROJECT ENGINEERING CONSULTANTS 64/5, 1st Floor 8th Main road, Vasanth nagar, Bangalore-560 052 Tele-22284583,22204836 E-mail - gprojecte@mjassociates.in/www.mjassociates.in	DRAWN	ABHI
				CHECKED	BGK
PROJECT: LABORATORY INTERIOR WORKS FOR CHEMICAL SCIENCES BUILDING.	DRAWING TITLE: P&ID FOR FUTURE GAS FOR IPC-2	DRAWING STATUS : TENDER DRAWINGS		APPROVED	SUNDAR
				DATE	24.03.2019
				JOB NO	MJ - 324
				DWG NO:	4814 (j)
				SCALE	NTS
				REVISION	TR 0